

# CERTIFICATE OF COMPLIANCE



## Hunter Douglas

### M Screen

Restrictions:

5396-420

Certificate Number

01/10/2008 - 02/16/2019

Certificate Period

Certified

Status

UL 2818 - 2013 Gold Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Window treatments are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using an Office and Classroom Environment.

Product tested in accordance with UL 2821 test method to show compliance to emission limits on UL 2818. Section 7.1 and 7.2.



**Environment**

## GREENGUARD Gold Certification Criteria for Building Products and Interior Finishes

| Criteria                                       | CAS Number | Maximum Allowable Predicted Concentration | Units             |
|--|------------|---|-------------------|
| TVOC <sup>(A)</sup>                            | -          | 0.22                                      | mg/m <sup>3</sup> |
| Formaldehyde                                   | 50-00-0    | 9 (7.3 ppb)                               | µg/m <sup>3</sup> |
| Total Aldehydes <sup>(B)</sup>                 | -          | 0.043                                     | ppm               |
| 4-Phenylcyclohexene                            | 4994-16-5  | 6.5                                       | µg/m <sup>3</sup> |
| Particle Matter less than 10 µm <sup>(C)</sup> | -          | 20  | µg/m <sup>3</sup> |
| 1-Methyl-2-pyrrolidinone <sup>(D)</sup>        | 872-50-4   | 160                                       | µg/m <sup>3</sup> |
| Individual VOCs <sup>(E)</sup>                 | -          | 1/2 CREL<br>or<br>1/100th TLV             | -                 |

- (A) Defined to be the total response of measured VOCs falling within the C<sub>6</sub> – C<sub>16</sub> range, with responses calibrated to a toluene surrogate. Maximum allowable predicted TVOC concentrations for GREENGUARD Gold (0.22 mg/m<sup>3</sup>) fall in the range of 0.5 mg/m<sup>3</sup> or less, as specified in CDPH Standard Method v1.2.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Particle emission requirement only applicable to HVAC Duct Products with exposed surface area in air streams (a forced air test with specific test method) and for wood finishing (sanding) systems.
- (D) Based on the CA Prop 65 Maximum Allowable Dose Level for inhalation of 3,200 µg/day and an inhalation rate of 20 m<sup>3</sup>/day
- (E) Allowable levels for chemicals not listed are derived from the lower of 1/2 the California Office of Environmental Health Hazard Assessment (OEHHA) Chronic Reference Exposure Level (CREL) as required per the CDPH/EHLB/Standard Method v1.2 and BIFMA level credit 7.6.2 and 1/100th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).



**Environment**