

# Certificate of Compliance

## Certificate

69945-420

## Issue Date

06 Oct 2023

## Expiration Date

27 Jul 2026



A handwritten signature in black ink that reads 'Rane Valles'.

Rane Valles  
Director and General Manager

UL Verification Services Inc.  
2211 Newmarket Parkway, ste 106  
Marietta, GA 30067 USA

UL Verification Services does hereby certify that an independent assessment has been conducted on behalf of:

**USG**

for the following product:

**Radar™ High-CAC Acoustical Panels**

The product has been evaluated and meets the requirements for:

**GREENGUARD Gold**

UL 2818 - 2022 Gold Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

*Building products and interior finishes are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using an Office and Classroom Environment.*



UL Solutions evaluated representative samples of the identified product, process or facility to the identified Standard or other requirements in accordance with the agreements and any applicable program service terms in place between UL Solutions and the Client (collectively "Agreement"). The Client is authorized to use the UL Mark for the identified Product, process or facility covered by this certificate, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement. This certificate is subject to modification, suspension and withdrawal by UL Solutions see SPOT.ul.com, to authenticate the certificate.

# Certificate of Compliance

## GREENGUARD Gold Certification Criteria for Building Products and Interior Finishes

| Criteria                                       | CAS Number | Maximum Allowable Predicted Concentration | Units             |
|--|------------|---|-------------------|
| TVOC <sup>(A)</sup>                            | -          | 0.22                                      | mg/m <sup>3</sup> |
| Formaldehyde                                   | 50-00-0    | 9 (7.3 ppb)                               | µg/m <sup>3</sup> |
| Total Aldehydes <sup>(B)</sup>                 | -          | 0.043                                     | ppm               |
| 4-Phenylcyclohexene                            | 4994-16-5  | 6.5                                       | µg/m <sup>3</sup> |
| Particle Matter less than 10 µm <sup>(C)</sup> | -          | 20  | µg/m <sup>3</sup> |
| 1-Methyl-2-pyrrolidinone <sup>(D)</sup>        | 872-50-4   | 160                                       | µg/m <sup>3</sup> |
| Individual VOCs <sup>(E)</sup>                 | -          | 1/2 CREL<br>or<br>1/100th TLV             | -                 |

- (A) Defined to be the total response of measured VOCs falling within the C<sub>6</sub> – C<sub>16</sub> range, with responses calibrated to a toluene surrogate. Maximum allowable predicted TVOC concentrations for GREENGUARD Gold (0.22 mg/m<sup>3</sup>) fall in the range of 0.5 mg/m<sup>3</sup> or less, as specified in CDPH Standard Method v1.2.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Particle emission requirement only applicable to HVAC Duct Products with exposed surface area in air streams (a forced air test with specific test method) and for wood finishing (sanding) systems.
- (D) Based on the CA Prop 65 Maximum Allowable Dose Level for inhalation of 3,200 µg/day and an inhalation rate of 20 m<sup>3</sup>/day
- (E) Allowable levels for chemicals not listed are derived from the lower of 1/2 the California Office of Environmental Health Hazard Assessment (OEHHA) Chronic Reference Exposure Level (CREL) as required per the CDPH/EHLB/Standard Method v1.2 and BIFMA level credit 7.6.2 and 1/100th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).



*UL Solutions evaluated representative samples of the identified product, process or facility to the identified Standard or other requirements in accordance with the agreements and any applicable program service terms in place between UL Solutions and the Client (collectively "Agreement"). The Client is authorized to use the UL Mark for the identified Product, process or facility covered by this certificate, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement. This certificate is subject to modification, suspension and withdrawal by UL Solutions see SPOT.ul.com, to authenticate the certificate.*